



JAMAICA PUBLIC SERVICE COMPANY, LIMITED

BELLEVUE 138/69KV SUBSTATION PROJECT

REQUEST FOR PROPOSALS

The Supply of -

STEEL STRUCTURES AND BUSWORK FOR INSTALLATION AT BELLEVUE SUBSTATION

RFP # 987999

Questions and Answer
Addendum #1

JUNE 2024

Purchasing and Customs

113 Washington Boulevard Kingston

JPS Co. Ltd., Jamaica

Questions and Answer

The below questions were asked and JPS provided the following responses.

1. Clause TS.01.4: Drawing 598-91-BE9D-HHS: Bellevue 138kV Substation High Switch Stand is missing from the tender package. Please provide.

JPS Response – [See attached](#)

2. Clause TS.01.4 : Equipment outline drawings (138kV Disconnect Switches, 69kV Disconnect Switches, 138kV PT's, 69kV PT's) are missing. Please provide.

JPS Response – [See attached](#)

3. Clause TS.01.1 : Scope of Work states design of the steel structures. However the tender already includes the drawings for the steel structures that are required. Why is the Supplier suppose to design the structures again?

JPS Response- [Note that drawing "598-91-BE9D-HHS: Bellevue 138kV Substation High Switch Stand" identifies only dimensions and anchor bolt layout requirements for that specific structure and as such the designs need to be completed only for that structure. All other structures can be supplied as per drawings provided.](#)

4. Clause TS.01.1 : Scope of Work states Substation layout, Substation section and BOM. But the tender already has a list of connectors with part numbers that are to be supplied. What engineering is therefore needed?

JPS Response – [No detailed engineering is required.](#)

5. Can you please clarify the following clause in the bid documents:

General Conditions of Contract

GC.12.2 Prices charged by the Supplier for the preceding incidental services, shall not be included in, shall be quoted separately in the Contract Price for the Goods, shall be agreed upon in advance by the parties and shall not exceed the prevailing rates charged by other parties by the Supplier for similar services.

JPS Response – [This does not apply to this request as the services stated in GC. 12.1 is not required.](#)

Addendum

IB.18 Deadline for Submission of Bids

IB.18.1 Bids must be received by the Purchaser at the address specified under para. IB.18.1 no later than 11:59 pm Eastern Standard Time on July 18, 2023.

RFP CALENDAR		
ACTIVITY	DUE DATE	RESPONSIBILITY
RFP date	June 14, 2024	JPS
Bidder submits questions on RFP	June 20, 2024	Bidder
Final date to respond to all queries	June 25, 2024	JPS
Bidders provide their intention to bid	July 5, 2024	Bidder
Completion of RFP and deadline for submission of bids to JPS	July 18, 2024	Bidder
Bid Opening	July 19, 2024	JPS