



February 27<sup>th</sup>, 2025

## **ADDENDUM 1- JPS RFP # 1015199- GT10 Generator GAP 3, Corona and Life Extension Work Plan**

The purpose of this addendum is to provide feedback to queries received regarding this RFP. Note the queries as well as JPS' feedback (in blue) below:

### **1.1 INTRODUCTION**

- a. Please confirm the starting date for the inspection – whether it will be performed at the same time as the major inspection for GT10.

**JPS Response:** Yes, it will be performed at the same time as the major inspection on GT10 which is currently scheduled to take place in December 2025. Bidders are required to provide all paint and other materials that may be needed to address this issue.

- b. Please provide additional details regarding the corona and partial discharge issues in the generator stator. Please provide a copy of the last inspection report detailing the issues/recommendations.

**JPS Response:** Based on an online Electromagnetic Signature Analysis (EMSA) survey done in 2025, no significant corona and partial discharge activity was observed, there has been a downward trend when compared to previous EMSA online surveys conducted on GT10 in 2021 and 2023. This downward trend may be due to degradation of the areas, hence the need to carry out this assessment and action during this time for Life extension. JPS is not in a position to share the requested inspection report at this time.

### **4.1 Bid Response**

Please provide a one (1)-week extension to the due date for submitting questions (currently February 24), to allow our team for additional questions.

**JPS Response:** We will grant an extension of the timeline for question submission to Tuesday March 4<sup>th</sup> 2025 for JPS response by Thursday March 6<sup>th</sup> 2025.

Note however, that we are not able to grant any corresponding extensions to the deadline for proposal submission.

## **APPENDIX III**

### **3.7 Generator Rotor Retaining Rings Off Intervention**

- a. Please confirm if JPSCo will provide the retaining ring insulation material.

**JPS Response:** The supplier will be responsible for providing this.

**[END OF DOCUMENT]**