



JAMAICA PUBLIC SERVICE COMPANY, LIMITED

ALCAN T1 TRANSFORMER REPLACEMENT

REQUEST FOR PROPOSALS

The Supply of -

One (1) 6.0MVA, 69 – 3.45KV POWER TRANSFORMER

RFP # 966748-RETENDER

Addendum # 1

February 2025
Purchasing and Customs Department
113 Washington Boulevard Kingston
JPS Co. Ltd., Jamaica

IB.19**Deadline for Submission of Bids**

IB.19.1

Bids must be received by the Purchaser at using the method specified under para. IB.18.1 no later than **11:59 pm Eastern Standard Time on March 6, 2025.**

RFP CALENDAR		
ACTIVITY	DUE DATE	RESPONSIBILITY
RFP date	February 7, 2025	JPS
Bidder submits questions on RFP	February 13, 2025	Bidder
Final date to respond to all queries	February 18, 2025	JPS
Bidders provide their intention to bid	February 20, 2025	Bidder
Completion of RFP and deadline for submission of bids to JPS	March 6, 2025	Bidder
Bid Opening	March 7, 2025	JPS

TS.03.4**Transformer Ratings**

Rated Capacity		6.0 MVA
Temperature Rise		65°C above 40°C ambient
Cooling		ONAN
Rated Frequency		50 Hz
Rated Voltage	-high	69 kV
	-Low	3.45 kV
Connection	-	See table below
Vector Grouping	-	See table below
Rated Impedance Voltage not less at Base MVA		6.0 - 8.0%
BIL	-	See table below

Item	Rating	Connection	Vector Group	BIL
1	6.0 MVA 69 / 3.45 kV	Primary delta Secondary delta	Dd0	Primary 350KV Secondary 60KV